

# Declaration of performance



No. **12013012**

Product type **One-gang box HWD 90**

Type number **9463-01**

Intended place of use Installation boxes for the fire protection sealing of openings in fire protection walls

Manufacturer **Kaiser GmbH & Co. KG  
Ramsloh 4  
58579 Schalksmühle**

System for assessing and inspecting the constancy of performance **1**

*Notified body with details of their activities in respect of the product type listed above in accordance with European technical assessment*

The notified body of the "Materialprüfanstalt für das Bauwesen Braunschweig" (Materials Testing Institute for Construction Materials Brunswick) has carried out the initial inspection of the factory and the company's own production control in addition to the on-going monitoring, assessment and evaluation of the in-house production control in accordance with System 1, and has issued a certificate of conformity in accordance with the requirements of ETA-18/0091: **0761-CPR-0749**

*Notified body with details of their activities in respect of the product type listed above in accordance with the harmonised standard*

Not relevant

## Declared performance

Fire resistance **E 90** EN 13501-2

Class of fire behaviour **E** EN 13501-1

Declaration The product described complies with the performance characteristics. The manufacturer bears sole responsibility for the generation of this declaration of performance.

## Miscellaneous:

The product described also complies with the requirements of **Low Voltage Directive 2014/35/EU**. Compliance of this product with the requirements of the guideline is shown by the full adherence to the following standard:

**DIN EN 60670-1: 2005-10**  
**DIN EN 60670-22: 2007-07**

Name and function Dirk Umbach, Director Market and Innovation Development

Schalksmühle, 14.06.2019

Place and date of issuance

Signature

A handwritten signature in black ink, appearing to be "DU", written over a horizontal line.