

Certificate

about the quality of airtightness

Component: One-gang box ECON[®], Art.-No. 9263-22
One-gang box ECON[®], halogen-free, Art.-No. 9263-78

Customer: Kaiser GmbH & Co. KG, Ramsloh 4, 58579 Schalksmühle

Test Object:

Housing consisting of plastic-coated chipboards with therein installed
10 one-gang boxes ECON[®] (Art.-No. 9263-22) and 10 one-gang boxes
ECON[®], halogen-free (Art. No. 9263-78) with 8 conduit and 24 cable entries.

Results:

Using the BlowerDoor Micro-Leakage-Meter measurement system and the DG-700
the following values for the airflow and the permeability of building components
at a pressure difference of 10 Pa were achieved:

Airflow at 50 Pascal based on 20 one-gang boxes ECON[®]
with 32 cable and conduit entries:

$$V_{50} = 0,2112 \text{ m}^3/\text{h}$$

Airflow at 10 Pascal relative to the joint length (permeability of building component):

$$\text{leakage rate} = 0,0084 \text{ m}^3/(\text{h}\cdot\text{m})$$

According to DIN 4108-2:2013-02 chapter 7 para. 3, the requirement for component connection joints is $\leq 0.1 \text{ m}^3/\text{mh} (\text{daPa}^2/3)$.

**The tightness of component connection joints of the one-gang box ECON[™]
and the one-gang box ECON[®], halogen-free (Art.-No. 9263-22, 9263-78)
satisfies the requirements.**



24.01.2018

Dipl.-Ing. Heiko Wandtke

Ingenieurgesellschaft
Bau + Energie + Umwelt GmbH
Zum Energie- und Umweltzentrum 1
31832 Springe-Eldagsen
Telefon 05044 / 975-30
Telefax 05044 / 975-44